

Form A – IIG Design Discussion Request

Discussion Request Number	Title	Priority
<i>DR 0120</i>	Rejection of change of usage requests DG5 to 1 or 2 where MIC is greater than or equal to 30 kVA.	<i>Med</i>

Name of Requesting Organisation	<i>RMDS</i>
Contact name	Tim Cragg
Date Request sent to RMDS	28th August 2006

Detail of Discussion Request
<p>Suppliers can currently request a change of usage for a premises they supply using Market Message 013 as follows:</p> <ul style="list-style-type: none"> • Change of usage from Residential to Commercial • Change of usage from Commercial to Residential <p>A change from Commercial to Residential means that (if verified by Networks) the DUoS group also changes from DG5 to DG1 or 2.</p> <p>The DUoS rules provide that business DUoS tariffs apply to any premises with an MIC of 30 kVA or greater. This validation on the 013 was added to the implementation on the central market system in the past to speed processing of requests: if the site has a Maximum Import Capacity (MIC) of 30 kVA or more a change from Commercial to Residential is invalid and is rejected using Market Message 014R (Rejection Code ICU).</p> <p>However the documentation was not updated with this change. It is proposed to resolve this by amending the market design to include this validation in MPD24. Suggested wording to be added to the MPD is as follows:</p> <p style="color: blue;">If a Change of Customer Details request includes a request to change the usage type of a site from Commercial to Residential ESB Networks will validate that the site has a Maximum Import Capacity (MIC) of less than 30kVA. If the MIC is equal to or greater than 30kVA the requested change of usage will be deemed invalid and rejected using Market Message 014R (Rejection Code ICU).</p>
Reason for Discussion Request
This DR is requested to add clarity around this particular aspect of the Market Process
Market Design Documents impacted by Request
<i>MPD 24 Change of Customer Details v5.1</i>
Date of IGG where

discussed	
Change Request xref (if applicable)	

PART 2 MARKET ASSURANCE:				
Applicability				
ESB Networks	Suppliers	TSO	SSA	Generators
x	x			
Scope of Test				
Connectivity	DTT	MSA	IPT	Other
			No. Of Scenarios	

Scope of Discussion Request							
Correction to Documentation	Business Process	Market & MP Systems	MPCC	Readings Processor	Market Gateway	Schema	Web Forms
x	x						